

# Appendix A to OWTS ECDHHS On-Site Waste Water Treatment System 2018

**Local Public Health Agency:** Elbert County Department of Health and Human Services

| CROSSWALK   |   |                                     |                     |                       |
|---|---|-------------------------------------|---------------------|-----------------------|
| ITEM  | REQUIREMENTS<br>See Check Box for Decision Chosen.  |                                     | Citation<br>Reg #43 | Citation<br>Local Reg |
| Occupancy – Residential   | Bedrooms 1 through 3: 2 people per bedroom<br>All additional Bedrooms: 1 person per bedroom   | <input checked="" type="checkbox"/> | 43.6.A.2e           | p 39                  |
|   | All bedrooms: 2 persons per bedroom   | <input type="checkbox"/>            | 43.6.A.2.f          |                       |
| How the number of bedrooms in a home will be defined for flow requirements  | Bedrooms: flow estimates will be determined from the number of bedrooms originally finished.  | <input checked="" type="checkbox"/> |                     | p 39                  |
|   | If unfinished area is present in house, system must also be sized for 1 or 2 more bedrooms based on an assumption that 150 square feet of unfinished space can be converted into a bedroom, if the space can meet applicable code requirements for a bedroom. | <input type="checkbox"/>            | 43.6.A.2.h          |                       |
| Effluent Screen   | May be used ( <i>owner's option</i> )   | <input checked="" type="checkbox"/> | 43.9.J.1            | p 61                  |
|   | Required in all new septic tanks  | <input type="checkbox"/>            | 43.9.J.1            |                       |
| Length of Distribution Laterals (e.g., trenches or beds)  | Limit the length of distribution lines to a maximum of 100 feet.  | <input checked="" type="checkbox"/> | 43.10.E.2.c         | p 67                  |
|   | 100 feet maximum for gravity fed from one end, and up to 150 feet if pressure dosed or effluent applied at center of lateral or chamber   | <input type="checkbox"/>            | 43.10.E.2.b & c     |                       |
| Inspection ports at initial (front) end of distribution line (e.g., lateral or chamber)                                 | Not required  | <input type="checkbox"/>            |                     |                       |
|   | Required  | <input checked="" type="checkbox"/> | 43.10.F.6.d         | p 72                  |
| Vault Privies – new   | Allow new vault privies   | <input type="checkbox"/>            | 43.12.D.1.a         |                       |
|   | Prohibit new vault privies  | <input checked="" type="checkbox"/> | 43.12.D.1.a         | p 91                  |
| Vault Privies - existing  | Allow continued use of existing vault privies   | <input checked="" type="checkbox"/> | 43.12.D.1.b         | p 91                  |
|   | Require abandonment of existing vault privies   | <input type="checkbox"/>            | 43.12.D.1.b         |                       |
| Pit Privies - new   | Allow new pit privies   | <input type="checkbox"/>            | 43.12.D.2.c         |                       |
|   | Prohibit new pit privies  | <input checked="" type="checkbox"/> | 43.12.D.2.a         | p 92                  |
| Pit Privies - existing  | Allow continued use of existing pit privies   | <input checked="" type="checkbox"/> | 43.12.D.2.c         | p 92                  |
|   | Require abandonment of existing pit privies   | <input type="checkbox"/>            | 43.12.D.2.b         |                       |
| Slit trenches   | Allow slit trenches   | <input type="checkbox"/>            | 43.12.F             |                       |
|   | Prohibit slit trenches  | <input checked="" type="checkbox"/> | 43.12.F             | p 93/94               |
| Reductions in STA size or separation distances for higher level treatment systems; OWTS O/M and LPHA oversight required | Allow reductions for higher level treatment.  | <input type="checkbox"/>            | 43.14.D.2           |                       |
|   | Reductions for higher level treatment not allowed   | <input checked="" type="checkbox"/> | 43.14.D.3           |                       |
| Transfer of Title inspections   | Inspection of OWTS required prior to transfer of title  | <input checked="" type="checkbox"/> | 43.4.L.1            |                       |
|   | Inspection of OWTS NOT required   | <input type="checkbox"/>            | 43.4.L.1            |                       |