

AMENDMENTS FOR 2006 INTERNATIONAL FUEL GAS CODE

1. **DELETION AND SUBSTITUTION (DEPARTMENT OF PLUMBING INSPECTION) Sec. 103 Department of PLUMBING Inspection.**
Delete Sec. 103 in its entirety.
2. **DELETION AND SUBSTITUTION (FEES) Sec. 106.5 Fees.**
Delete Sec. 106.5 in its entirety and substitute the following: A fee for each permit shall be paid as required and shall be based on Resolution 06-42 from the Building Safety Journal August 2005 edition (to be up dated as necessary for market cost fluctuation). Annual permit fees are established by the building official.
3. **DELETION AND SUBSTITUTION (FEE REFUNDS) Sec. 106.5.3 Fee Refunds**
Delete Sec. 106.5.3 in its entirety and substitute the following: The building official may authorize refunding of any fee paid hereunder which was erroneously paid or collected.

The building official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code.

The building official may authorize refunding of not more than 80 percent of the plan review fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or canceled before any plan reviewing is done.

The building official shall not authorized refunding of any fee paid except on written application filed by the original permittee not later than 180 days after the date of fee payment.
4. **DELETION AND SUBSTITUTION (MEANS OF APPEAL) Sec. 109 Means of Appeal**
Delete Sec. 109 in its entirety and substitute the following: There shall be a board of appeals created when necessary.
5. **DELETION AND SUBSTITUTION ELECTRICAL) Sec. 309/310**
Delete Sec. 309/310 in their entirety and substitute the following: All electrical must be resolved with the most current NEC adopted and enforced by the State of Colorado Electrical Board
6. **DELETION AND SUBSTITUTION (TEST PRESSURE) Sec. 406.4.1 Test Pressure.**
Delete Sec. 406.4.1 in its entirety and substitute the following: The test pressure to be used shall be not less than one and one-half times the proposed maximum working pressure, but not less than 20 psig (20 kPa gauge), irrespective of design pressure. Where the test pressure exceeds 125 psig (862 kPa gauge), the test pressure shall not exceed a value that produces a hoop stress in the piping greater than 50 percent of the specified minimum yield strength of the pipe.
7. **DELETION AND SUBSTITUTION (TEST DURATION) Sec. 406.4.2 Test Duration.**
Delete Sec. 406.4.2 in its entirety and substitute the following: The test duration shall be not less than 20 minutes.
8. **DELETION AND SUBSTITUTION (EQUIPMENT SHUT OFF VALVE) Sec. 409.5 Equipment shutoff valve.**
Delete Sec. 409.5 in its entirety and substitute the following: Each appliance shall be provided with a shut off valve separate from the appliance. The shut off valve shall be located in the same room as the appliance, not further than 6 feet from the appliance, and shall be readily accessible. When using (CSST) each appliance shall be provided with a shut off valve separate from the appliance. The shut off valve shall be located at the manifold that serves each individual appliance. All shut off valves shall be installed up stream from the union, connector or quick disconnect device it serves. Such shut off valves shall be provided with access.